



## KOTTAYAM MUNICIPALITY

H2/10770/2022

Dated: 23/05/2022

### SANITATION CERTIFICATE

As per the inspection report of the Health inspector of this institution dated 23/05/2022 I here by certified that the Sanitation condition of Excelsior English School ,Kottayam is satisfactory to the health point of view by maintaining the required standards at the time of inspection.

Kottayam

23/05/2022




  
23/05/22  
Health Supervisor

Kottayam Municipality

M. S. ANU  
Health Supervisor  
Kottayam Municipality

  
PRINCIPAL  
EXCELSIOR ENGLISH SCHOOL  
KOTTAYAM

EXCELSIOR ENGLISH SCHOOL

  
Rosey Mathew  
Correspondent

Telephone No. 0481 2302391  
Email- aeqcldktm@gmail.com



**KERALA WATER AUTHORITY**  
**QUALITY CONTROL DISTRICT LAB, KOTTAYAM**  
**Water Analysis Report**

Report No. K293/KTM/03/2022

Date :05.04.2022

Customer Name & Address PRINCIPAL EXCELSIOR ENGLISH SCHOOL KOTTAYAM WEST P.O KOTTAYAM	1.Date of Receipt	21.03.2022
	2.Sampling done by	Self
	3.Sample Code	2022/QC/KTM/K1034
	4.Source of Sample	Open well
	5.Sample Quantity	100 ml
	6.Test performing dates	From 21.03.2022 to 22.03.2022

**BACTERIOLOGICAL ANALYSIS**

Sl No.	Parameters	Acceptable limits as per -IS 10500-2012	Test Method	Result
1	Coliforms	Shall not be detected/100ml	IS 15185:2016	Present
2	E-coli	Shall not be detected/100ml	IS 15185:2016	Absent

Remarks:-

NB:- The result stated above related only to the sample(s) submitted for testing. This test Certificate shall not be reproduced except in full without the written approval of the laboratory

\*End of the Report\*

*Always*  
Authorized By

Page 1 -1

*Shandy*  
PRINCIPAL  
EXCELSIOR ENGLISH SCHOOL  
KOTTAYAM  
Office of the Asst. Engineer  
KOTTAYAM  
Date.....  
Quality Control District Lab. K. W. A.

EXCELSIOR ENGLISH SCHOOL

*Rosey Mathew*  
Rosey Mathew  
Correspondent