

Telephone No. 0481 2302391
Email- aeqcldktm@gmail.com



KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LAB, KOTTAYAM
Water Analysis Report

Report No. K293/KTM/03/2022

Date :05.04.2022

Customer Name & Address PRINCIPAL EXCELSIOR ENGLISH SCHOOL KOTTAYAM WEST P.O KOTTAYAM	1.Date of Receipt	21.03.2022
	2.Sampling done by	Self
	3.Sample Code	2022/QC/KTM/K1034
	4.Source of Sample	Open well
	5.Sample Quantity	100 ml
	6.Test performing dates	From 21.03.2022 to 22.03.2022


BACTERIOLOGICAL ANALYSIS

Sl No.	Parameters	Acceptable limits as per -IS 10500-2012	Test Method	Result
1	Coliforms	Shall not be detected/100ml	IS 15185:2016	Present
2	E-coli	Shall not be detected/100ml	IS 15185:2016	Absent



Remarks:-

NB:- The result stated above related only to the sample(s) submitted for testing. This test Certificate shall not be reproduced except in full without the written approval of the laboratory

End of the Report


Authorized By

Page 1 -1


PRINCIPAL
EXCELSIOR ENGLISH SCHOOL
KOTTAYAM


EXCELSIOR ENGLISH SCHOOL


Rosey Mathew
Correspondent